

c. *Date filed*: September 29, 1999  
 d. *Applicant*: Northbrook Energy, LLC  
 e. *Name of Project*: Hamilton Hydroelectric Project  
 f. *Location*: Ford Canal and Great Miami River, Butler County, Ohio. The project would not utilize federal lands.  
 g. *Filed Pursuant to*: Federal Power Act, 16 U.S.C. 791(a)-825(r).  
 h. *Applicant Contact*: Northbrook Energy, LLC, 225 W. Wacker Drive, Suite 2330, Chicago, IL 60606, or telephone (312) 553-2131.  
 i. *FERC Contact*: Any questions on this notice should be addressed to Nick Jayjack, E-mail address [nicholas.jayjack@ferc.fed.us](mailto:nicholas.jayjack@ferc.fed.us) or telephone (202) 219-2825.

j. *Deadline for filing additional study request*: November 29, 1999

All documents (original and eight copies) should be filed with: David P. Boergers, Secretary, Federal Energy Regulatory Commission, 888 First Street, NW, Washington, DC 20426.

The Commission's Rules of Practice and Procedure require all intervenors filing documents with the Commission to serve a copy of that document on each person whose name appears on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. *Status of environmental analysis*: This application is not ready for environmental analysis at this time.

l. *Description of the Project*: The project consists of: (1) an 8-foot-high (average), 1,660-foot-long concrete overflow diversion dam; (2) an 8-foot-high (average), 196-foot long concrete overflow diversion dam; (3) a 3-mile-long power canal; (4) a concrete headgate structure at the canal entrance; (5) a 93-foot-wide by 63-foot-long by 50-foot-high powerhouse with an installed capacity of 1,500 kilowatts (kW) to be upgraded to 2,250 kW (the turbine-generator units are currently capable of producing 1,940 kW; however, system governors limit output to 1,500 kW); (6) a 21-foot-long spillway adjacent to the powerhouse; (7) a 50-foot-wide, 1,600-foot-long concrete and earthen tailrace; (8) a 0.25-mile-long, 13.2 kilovolt transmission line; (9) generator leads; and (10) appurtenant facilities.

m. *Location of the application*: A copy of the application is available for inspection and reproduction at the Commission's Public Reference Room, located at 888 First Street, NE, Room 2A, Washington, DC 20426, or by calling (202) 208-1371. The application may be

viewed on the web at <http://www.ferc.fed.us/online/rims.htm> (call (202) 208-2222 for assistance). A copy is also available for inspection and reproduction at the address in item h above.

n. With this notice, we are initiating consultation with the State Historic Preservation Officer as required by § 106, National Historic Preservation Act, and the regulations of the Advisory Council on Historic Preservation, 36 CFR 800.4.

**David P. Boergers,**

*Secretary.*

[FR Doc. 99-27480 Filed 10-20-99; 8:45 am]

BILLING CODE 6717-01-M

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Application Tendered for Filing With the Commission, Establishing a Deadline for Final Amendment, and Soliciting Additional Study Requests

October 15, 1999.

Take notice that the following hydroelectric application has been filed with the commission and is available for public inspection:

a. *Type of application*: New Major License  
 b. *Project No.*: 2416-009  
 c. *Date filed*: October 5, 1999  
 d. *Applicant*: Aquenergy Systems Inc.  
 e. *Name of project*: Ware Shoals Project.

f. *Location*: On Saluda River in the Town of Ware Shoals, within the counties of Laurens, Greenwood and Abbeville, South Carolina. No Federal Lands used in this project.

g. *Filed pursuant to*: Federal Power Act, 16 U.S.C. 791(a)-825(r).

h. *Applicant contact*: Beth Harris, P.E., CHI Energy, Inc., P.O. 5897, Greenville, SC 29604, (864) 281-9630 Ext. 105.

i. *FERC contact*: Any questions on this notice should be addressed to Timothy Looney, E-mail address, [timothy.looney@ferc.fed.us](mailto:timothy.looney@ferc.fed.us), or telephone 202-219-2852.

j. *Deadline for filing final amendments*: February 5, 2000.

k. *Deadline for filing additional study requests*: December 6, 1999.

All documents (original and eight copies) should be filed with: David P. Boergers, Secretary Federal Energy Regulatory Commission, 888 First Street, NE, Washington, DC 20426.

The Commission's rules of practice and procedure require all intervenors

filing documents with the commission to deserve a copy of that document on each person whose name appears on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

l. *Status of environmental analysis*: This application is not ready for environmental analysis at this time.

m. The existing project consists of a dam and reservoir, a power canal and two turbine generating units with a total nameplate rating of 6,200-kilowatts, and appurtenant facilities. The project would have an annual generation of 23,500,000 kilowatt hours. The applicant does not propose any modifications to the project features or operation.

n. A copy of the application is available for inspection and reproduction at the Commission's Public Reference Room, located at 888 First Street, NE, Room 2A, Washington, DC 20426, or by calling (202) 208-1371. This filing may be viewed on the web to <http://www.ferc.fed.us/online/rims.htm> call 202-208-2222 for assistance). A copy is also available for inspection and reproduction at the address in item h above.

o. With this notice we are initiating consultation with the South Carolina State Historic Preservation Officer as required by § 106, National Historic Preservation Act, and the regulations of the Advisory Council on Historic Preservation, 36 CFR 800.4.

**David P. Boergers,**

*Secretary.*

[FR Doc. 99-27486 Filed 10-20-99; 8:45 am]

BILLING CODE 6717-01-M

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Declaration of Intention and Soliciting Comments, Motions To Intervene, and Protests

October 15, 1999.

Take notice that the following application has been filed with the Commission and is available for public inspection:

a. *Application Type*: Declaration of Intention.

b. *Docket No.*: DI99-11-000.

c. *Date Filed*: September 7, 1999.

d. *Applicant*: Michael R. Hamlin and Rita Jean.

e. *Name of Project:* Great Falls Electric Company Project.

f. *Location:* On Androscoggin River, Lewiston, Androscoggin County, Maine.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. § 791(a)–825(r).

h. *Applicant Contact:* Ms. Rita Jean, 4 Bailey Court, Lewiston, ME 04240 (207) 783–9728.

i. *FERC Contact:* Any questions on this notice should be addressed to Etta Foster at (202) 219–2679, or e-mail address: [etta.foster@ferc.fed.us](mailto:etta.foster@ferc.fed.us).

j. *Deadline for filing comments, protests and motions:* November 17, 1999.

All documents (original and eight copies) should be filed with: David Boergers, Secretary, Federal Energy Regulatory Commission, 888 First Street, N.E., Washington, DC 20426.

Please include the docket number (DI99–11–000) on any comments, protests or motions filed.

k. *Description of Project:* The proposed run-of-river project will consist of an existing 20-foot-long penstock; an intake rack; a powerhouse containing a proposed single vertical generator with a generating capacity of 600 kW; and appurtenant facilities. Proposed power generation will be used by applicant and the surplus sold wholesale.

When a Declaration of Intention is filed with the Federal Energy Regulatory Commission, the Federal Power Act requires the Commission to investigate and determine if the interests of interstate or foreign commerce would be affected by the project. The Commission also determines whether or not the project: (1) would be located on a navigable waterway; (2) would occupy public lands or reservations of the United States; (3) would utilize surplus water or waterpower from a government dam; or (4) if applicable, has involved or would involve any construction subsequent to 1935 that may have increased or would increase the project's head or generating capacity, or have otherwise significantly modified the project's pre-1935 design or operation.

l. *Locations of the Application:* A copy of the application is available for inspection and reproduction at the Commission's Public Reference Room, located at 888 First Street, N.E., Room 2A, Washington, D.C. 20426, or by calling (202) 208–1371. This filing may be viewed on <http://www.ferc.fed.us/online/rims.htm> (call (202) 208–2222 for assistance.) A copy is also available for inspection and reproduction at the address in item h above.

m. Individuals desiring to be included on the Commission's mailing list should

so indicate by writing to the Secretary of the Commission.

*Comments, Protests, or Motions to Intervene*—Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, .211, .214. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any comments, protests, or motions to intervene must be received on or before the specified comment date for the particular application.

*Filing and Service of Responsive Documents*—Any filings must bear in all capital letters the title "COMMENTS", "RECOMMENDATIONS FOR TERMS AND CONDITIONS", "PROTEST", OR "MOTION TO INTERVENE, as applicable, and the Project Number of the particular application to which the filing refers. Any of the above-named documents must be filed by providing the original and the number of copies provided by the Commission's regulations to: The Secretary, Federal Energy Regulatory Commission, 888 First Street, N.E., Washington, D.C. 20426. A copy of any motion to intervene must also be served upon each representative of the Applicant specified in the particular application.

*Agency Comments*—Federal, state, and local agencies are invited to file comments on the described application. A copy of the application may be obtained by agencies directly from the Applicant. If an agency does not file comments within the time specified for filing comments, it will be presumed to have no comments. One copy of an agency's comments must also be sent to the Applicant's representatives.

**David P. Boergers,**

*Secretary.*

[FR Doc. 99–27489 Filed 10–20–99; 8:45 am]

BILLING CODE 6717–01–M

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Application Tendered for Filing With the Commission and Soliciting Additional Study Requests

October 15, 1999.

Take notice that the following hydroelectric application has been filed

with the Commission and is available for public inspection:

a. *Type of Application:* Subsequent License.

b. *Project No.:* 2724–023.

c. *Date filed:* September 30, 1999.

d. *Applicant:* City of Hamilton, Ohio.

e. *Name of Project:* City of Hamilton Hydroelectric Project.

f. *Location:* Ford Canal and Great Miami River, Butler County, Ohio. The project would not utilize federal lands.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791(a)–825(r).

h. *Applicant Contact:* City Manager, City of Hamilton, Ohio, 20 High Street, Hamilton, OH 45011, or telephone (513) 868–5891.

i. *FERC Contact:* Any questions on this notice should be addressed to Nick Jayjack, E-mail address [nicholas.jayjack@ferc.fed.us](mailto:nicholas.jayjack@ferc.fed.us) or telephone (202) 219–2825.

j. *Deadline for filing additional study requests:* November 29, 1999.

All documents (original and eight copies) should be filed with: David P. Boergers, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE, Washington, D.C. 20426.

The Commission's Rules of Practice and Procedure require all intervenors filing documents with the Commission to serve a copy of that document on each person whose name appears on the official service list for the project.

Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. *Status of environmental analysis.* This application is not ready for environmental analysis at this time.

l. *Description of the Project:* The project consists of: (1) an 8-foot-high (average), 1,660-foot-long concrete overflow diversion dam; (2) an 8-foot-high (average), 196-foot-long concrete overflow diversion dam; (3) a 3-mile-long power canal; (4) a concrete headgate structure at the canal entrance; (5) a 93-foot-wide by 63-foot-long by 50-foot-high powerhouse with an installed capacity of 1,500 kilowatts (kW) to be upgraded to 1,940 kW (the turbine-generator units are currently capable of producing 1,940 kW; however, system governors limit output to 1,500 kW); (6) a 21-foot-long spillway adjacent to the powerhouse; (7) a 50-foot-wide, 1,600-foot-long concrete and earthen tailrace; (8) a 0.25-mile-long, 13.2-kilovolt transmission line; (9) generator leads; and (10) appurtenant facilities.

m. *Locations of the application:* A copy of the application is available for