

Dated: March 20, 2000.

Karen J. York,

Committee Meeting Officer.

[FR Doc. 00-7187 Filed 3-22-00; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-400]

Carolina Power & Light Company (Shearon Harris Nuclear Power Plant, Unit 1); Exemption

I

Carolina Power & Light Company (CP&L or the licensee) is the holder of Facility Operating License No. NPF-63, which authorizes operation of the Shearon Harris Nuclear Power Plant, Unit 1 (HNP) at power levels not to exceed 2775 megawatts thermal. The facility consists of one pressurized-water reactor located at the licensee's site in Wake and Chatham Counties, North Carolina. The license provides, among other things, that the licensee is subject to all rules, regulations, and orders of the Nuclear Regulatory Commission (NRC, the Commission) now or hereafter in effect.

II

Section IV.F.2.b of Appendix E to Title 10 of the Code of Federal Regulations (10 CFR) Part 50 requires each licensee at each site to conduct an exercise of its onsite emergency plan every 2 years and indicates the exercise may be included in the full-participation biennial exercise required by paragraph 2.c. Paragraph 2.c requires offsite plans for each site to be exercised biennially with full participation by each offsite authority having a role under the plan. During such biennial full-participation exercises, the NRC evaluates onsite emergency preparedness activities and the Federal Emergency Management Agency (FEMA) evaluates offsite emergency preparedness activities. CP&L successfully conducted a full-participation exercise for HNP during the week of October 7, 1997. By letter dated December 7, 1999, the licensee requested an exemption from Sections IV.F.2.b and c of Appendix E regarding the conduct of a full-participation exercise originally scheduled for September 21, 1999. Specifically, the licensee proposed rescheduling the exercise originally scheduled for September 21, 1999, and completing the onsite and offsite exercise requirements in two parts. The licensee would use the onsite exercise conducted on January

11, 2000, without the participation of the State of North Carolina and local government response agencies, to meet the onsite requirement. The offsite portion of the exercise would be conducted on June 27, 2000, with the participation of the State of North Carolina and local government response agencies.

The Commission, pursuant to 10 CFR 50.12(a)(1), may grant exemptions from the requirements of 10 CFR Part 50 that are authorized by law, will not present an undue risk to public health and safety, and are consistent with the common defense and security. The Commission, however, pursuant to 10 CFR 50.12(a)(2), will not consider granting an exemption unless special circumstances are present. Under 10 CFR 50.12(a)(2)(v), special circumstances are present whenever the exemption would provide only temporary relief from the applicable regulation and the licensee or applicant has made good faith efforts to comply with the regulation.

III

The licensee requests a one-time change in the schedule for the next full-participation exercise for HNP. Subsequent full-participation exercises for HNP would be scheduled at no greater than 2-year intervals in accordance with 10 CFR Part 50, Appendix E, Section IV.F.2.c. Accordingly, the exemption would provide only temporary relief from that regulation.

As indicated in the licensee's request for an exemption of December 7, 1999, the licensee had originally scheduled a full-participation exercise for September 21, 1999. As further set forth in that letter, however, due to the significant impact and damage from hurricane "Floyd," the State of North Carolina and the local emergency response agencies were occupied with responding to the natural disaster and were unable to participate in and could not support the exercise. In discussions on September 14, 1999, the NRC and FEMA indicated concurrence with rescheduling the exercise due to preparations and response to hurricane "Floyd." In a letter dated January 19, 2000, FEMA documented its support for rescheduling the exercise. Accordingly, the licensee made a good faith effort to comply with the schedule requirements of Appendix E for full-participation exercises.

The staff completed its evaluation of the licensee's request for an exemption. The staff, having considered the schedule and resource issues resulting from responding to hurricane "Floyd"

and the subsequent flooding, and the fact that the licensee conducted the onsite portion of the exercise on January 11, 2000, only 3 months beyond the required interval, finds the request acceptable.

IV

The Commission has determined that, pursuant to 10 CFR Part 50, Appendix E, this exemption is authorized by law, will not endanger life or property or the common defense and security, and is otherwise in the public interest. Further, the Commission has determined, pursuant to 10 CFR 50.12(a), that special circumstances of 10 CFR 50.12(a)(v) are applicable in that the exemption would provide only temporary relief from the applicable regulation and the licensee has made good faith efforts to comply with the regulation. Therefore, the Commission hereby grants the exemption from Section IV.F.2.b and c of Appendix E to 10 CFR Part 50.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will have no significant impact on the quality of the human environment (65 FR 14322).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 16th day of March 2000.

For the Nuclear Regulatory Commission.

John A. Zwolinski,

Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 00-7238 Filed 3-22-00; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-254 and 50-265]

Commonwealth Edison Company and Midamerican Energy Company; Notice of Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Commonwealth Edison Company (ComEd, or the licensee) to withdraw its August 31, 1998, application for proposed amendments to Facility Operating Licenses Nos. DPR-29 and DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, located in Rock Island County, Illinois.

The proposed amendment would have revised the maximum allowable Main Steam Isolation Valve leakage from 11.5 standard cubic feet per hour

(scfh) to 30.0 scfh when tested at 25 psig, in accordance with Technical Specification Surveillance Requirement 4.7.D.6.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on September 23, 1998 (63 FR 50935). However, by letter dated December 17, 1999, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated August 31, 1998, and the licensee's letter dated December 17, 1999, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 17th day of March 2000.

For the Nuclear Regulatory Commission.

Stewart N. Bailey,

Project Manager, Section 2, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 00-7240 Filed 3-22-00; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-346]

FirstEnergy Nuclear Operating Company (Davis-Besse Nuclear Power Station); Exemption

I

The FirstEnergy Nuclear Operating Company (FENOC, the licensee) is the holder of Facility Operating License No. NPF-3, which authorizes operation of the Davis-Besse Nuclear Power Station (DBNPS). The license provides, among other things, that the license is subject to all rules, regulations, and orders of the Commission now or hereafter in effect.

The facility consists of a pressurized-water reactor at the licensee's site in Ottawa County, Ohio.

II

Section 50.44 of Title 10 of the Code of Federal Regulations, "Standard for Combustible Gas Control System in Light-Water-Cooled Power Reactors," requires, among other items, that each boiling or pressurized light-water nuclear power reactor fueled with oxide

pellets within cylindrical zircaloy or ZIRLO cladding, must, as provided in paragraphs (b) through (d) of that section, include means for control of hydrogen gas that may be generated, following a postulated loss-of-coolant accident (LOCA) by—(1) Metal-water reaction involving the fuel cladding and the reactor coolant, (2) Radiolytic decomposition of the reactor coolant, and (3) Corrosion of metals.

Section 50.46 of Title 10 of the Code of Federal Regulations, "Acceptance Criteria for Emergency Core Cooling Systems for Light-Water Nuclear Power Reactors," requires, among other items, that each boiling or pressurized light-water nuclear power reactor fueled with uranium oxide pellets within cylindrical zircaloy or ZIRLO cladding must be provided with an emergency core cooling system (ECCS) that must be designed so that its calculated cooling performance following postulated LOCAs conform to the criteria set forth in paragraph (b) of that section. ECCS cooling performance must be calculated in accordance with an acceptable evaluation model and must be calculated for a number of postulated LOCAs of different sizes, locations, and other properties sufficient to provide assurance that the most severe postulated LOCAs are calculated.

Appendix K to Part 50 of Title 10 of the Code of Federal Regulations, "ECCS Evaluation Models," requires, among other items, that the rate of energy release, hydrogen generation, and cladding oxidation from the metal/water reaction shall be calculated using the Baker-Just equation.

10 CFR 50.44, 10 CFR 50.46, and 10 CFR part 50, Appendix K, make no provisions for use of fuel rods clad in a material other than Zircaloy or ZIRLO. The licensee has requested the use of Framatome Cogema Fuels (FCF) "M5" advanced alloy for fuel rod cladding for the DBNPS operating Cycle 13. The M5 alloy is a proprietary zirconium-based alloy comprised of primarily zirconium (~99 percent) and niobium (~1 percent). The elimination of tin has resulted in superior corrosion resistance and reduced irradiation induced growth relative to both standard Zircaloy (1.7% tin) and low-tin Zircaloy (1.2% tin). The addition of niobium increases ductility which is desirable to avoid brittle failures. Since the chemical composition of the M5 alloy differs from the specifications for Zircaloy or ZIRLO, a plant-specific exemption is required to allow the use of the M5 alloy as a cladding material at the DBNPS.

Section 50.12 of Title 10 of the Code of Federal Regulations, "Specific Exemptions," states, among other items,

that the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of the regulations of this part, which are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. The Commission will not consider granting an exemption unless special circumstances are present. Special circumstances are present whenever application of the regulation in the particular circumstances would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule.

III

The underlying purpose of 10 CFR 50.46 is to ensure that facilities have adequate acceptance criteria for ECCS. In its topical report BAW-10227P, "Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel," Framatome Cogema Fuels (FCF) demonstrated that the effectiveness of the ECCS will not be affected by a change from Zircaloy fuel rod cladding to M5 fuel rod cladding. Analysis described in the topical report also demonstrates that the ECCS acceptance criteria applied to reactors fueled with Zircaloy clad fuel are also applicable to reactors fueled with M5 fuel rod cladding.

The underlying purposes of 10 CFR 50.44 and 10 CFR part 50, Appendix K, paragraph I.A.5, are to ensure that cladding oxidation and hydrogen generation are appropriately limited during a LOCA and conservatively accounted for in the ECCS evaluation model. Specifically, Appendix K requires that the Baker-Just equation be used in the ECCS evaluation model to determine the rate of energy release, cladding oxidation, and hydrogen generation. In their topical report, FCF demonstrated that the Baker-Just model is conservative in all post-LOCA scenarios with respect to the use of the M5 advanced alloy as a fuel rod cladding material, and that the amount of hydrogen generated in an M5-clad core during a LOCA will remain within the DBNPS design basis.

The staff has reviewed the FCF's advanced cladding and structural material, M5, for pressurized water reactor fuel mechanical designs as described in BAW-10227P. In a Safety Evaluation dated February 4, 2000, the staff concluded that, to the extent and limitations specified in the staff's evaluation, the M5 properties and mechanical design methodology are acceptable for referencing in fuel reload