

Squaw Creek Reservoir approximately 5.2 miles (mi) north of Glen Rose, Texas.

The draft EIS was published by the NRC in August 2010; a notice of availability appeared in the **Federal Register** on August 12, 2010 (75 FR 48998). The purpose of this notice is to inform the public that the final EIS is available for public inspection. *The final EIS may be viewed online at: <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1943/>.* In addition, the final EIS is available for inspection in the NRC Public Document Room (PDR) located at One White Flint North, 11555 Rockville Pike Rockville, MD 20852 or from NRC's Agency-wide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html>. The final EIS is available in two volumes under accession numbers ML11131A001 and ML11131A002. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the PDR reference staff by telephone at 1-800-397-4209 and 1-301-415-4737 or by sending an e-mail to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). In addition, the Somervell County Library, 108 Allen Drive, Glen Rose, Texas 76043 and the Hood County Library, 222 North Travis Street, Granbury, Texas 76048 has agreed to make the EIS available to the public.

**FOR FURTHER INFORMATION CONTACT:** Mr. Michael Willingham, Environmental Projects Branch 1, U.S. Nuclear Regulatory Commission, Mail Stop T7-E30, Washington, DC 20555-0001. Mr. Willingham may be contacted by telephone at 301-415-3924 or via e-mail at [Michael.Willingham@nrc.gov](mailto:Michael.Willingham@nrc.gov).

Dated at Rockville, Maryland, this 13th day of May, 2011.

For the Nuclear Regulatory Commission.

**Gregory P. Hatchett,**

*Acting Deputy Director, Division of Site and Environmental Reviews, Office of New Reactors.*

[FR Doc. 2011-12446 Filed 5-19-11; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[DOCKET NO. 52-016; NRC-2008-0250]

### Calvert Cliffs 3 Nuclear Project, LLC and Unistar Nuclear Operating Services, LLC; Notice of Availability of the Final Environmental Impact Statement for the Combined License Application for Calvert Cliffs Nuclear Power Plant Unit 3

Notice is hereby given that the U.S. Nuclear Regulatory Commission (NRC) and the U.S. Army Corps of Engineers, as a cooperating agency, have published a final environmental impact statement (EIS), NUREG-1936, for the Calvert Cliffs Nuclear Power Plant (CCNPP), Unit 3 Combined License (COL) application. The site is located near the town of Lusby in Calvert County, Maryland, on the west shore of the Chesapeake Bay. A notice of availability of the draft EIS was published by the NRC in the **Federal Register** on April 21, 2010 (76 FR 20867), and by the U.S. Environmental Protection Agency on April 26, 2010 and April 30, 2010 (76 FR 21625 and 76 FR 22778).

The purpose of this notice is to inform the public that NUREG-1936, "Environmental Impact Statement for the Combined License for the Calvert Cliffs Nuclear Power Plant Unit 3: Final Report," is available for public inspection in the NRC Public Document Room (PDR) located at One White Flint North, 11555 Rockville Pike (First Floor) Rockville, MD 20852, or from the Publicly Available Records component of NRC Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at [www.nrc.gov/reading-rm/adams.html](http://www.nrc.gov/reading-rm/adams.html) which provides access through the NRC Electronic Reading Room link. The accession numbers in ADAMS for the final EIS are ML11129A167 and ML11129A179. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the PDR reference staff by telephone at 1-800-397-4209 or 1-301-415-4737, or by sending an e-mail to [PDR.resource@nrc.gov](mailto:PDR.resource@nrc.gov). The final EIS may also be viewed on the Internet at: <http://www.nrc.gov/reactors/new-reactors/col/calvert-cliffs/documents/nrc-2011.html>. In addition, the following public libraries in the vicinity of the CCNPP site have agreed to make the final EIS available for public inspection: Calvert Library, Southern Branch located at 20 Appeal Lane, Lusby, Maryland; and Calvert Library, Prince Frederick located at 850 Costley

Way, Prince Frederick, Maryland. The U.S. Environmental Protection Agency will also publish a Notice of Filing in the **Federal Register** which is expected to be on May 20, 2011. Such notices are published every Friday.

*For Further Information Contact:* Ms. Laura Quinn, Project Manager, Environmental Projects Branch 3, Division of Site and Environmental Reviews, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Ms. Quinn may be contacted by telephone at 301-415-2220, or via e-mail to [Laura.Quinn@nrc.gov](mailto:Laura.Quinn@nrc.gov).

Dated at Rockville, Maryland, this 13th day of May, 2011.

For the Nuclear Regulatory Commission.

**Gregory P. Hatchett,**

*Acting Deputy Director, Division of Site and Environmental Reviews, Office of New Reactors.*

[FR Doc. 2011-12458 Filed 5-19-11; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

### NORTHERN STATES POWER COMPANY

[Docket Numbers 50-282 and 50-306; NRC-2009-0507]

### Prairie Island Nuclear Generating Plant, Units 1 and 2; Notice of Availability of the Final Supplement 39 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding the License Renewal of Prairie Island Nuclear Generating Plants, Units 1 and 2

Notice is hereby given that the U.S. Nuclear Regulatory Commission (NRC) has published a final plant-specific supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, regarding the renewal of Operating Licenses DPR-42 and DPR-60 for an additional 20 years of operation for Prairie Island Nuclear Generating Plant, Units 1 and Unit 2 (PINGP 1 and 2). The PINGP 1 and 2 site is located near Red Wing, Minnesota, on the west bank of the Mississippi River in Goodhue County. Possible alternatives to the proposed action (license renewal) include the no action alternative and other reasonable alternative energy sources.

As discussed in Section 9.4 of the final supplement, the staff determined that the adverse environmental impacts of license renewal for PINGP 1 and 2 are not so great that preserving the option

of license renewal for energy-planning decision makers would be unreasonable.

This recommendation is based on: (1) The analysis and findings in the GEIS; (2) information provided in the environmental report and other documents submitted by Northern States Power Company; (3) consultation with Federal, State, local, and Tribal agencies; (4) the staff's own independent review; and (5) consideration of public comments received during the scoping process and on the draft Supplemental Environmental Impact Statement.

The final Supplement 39 to the GEIS is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, Public File Area O-1F21, 11555 Rockville Pike, Rockville, Maryland 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams.html>. The accession number for the final Supplement 39 to the GEIS is ML11133A029. Persons who do not have access to ADAMS or who encounter problems while accessing the documents located in ADAMS, should contact the NRC's PDR reference staff by telephone at (800) 397-4209 or (301) 415-4737, or by e-mail at [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). In addition, the Red Wing Public Library, 225 East Avenue, Red Wing, Minnesota 55066, has agreed to make the final supplement available for public inspection.

*For Further Information, Contact:* Ms. Elaine Keegan, Projects Branch 2, Division of License Renewal, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Mail Stop O-11F1, Washington, DC 20555-0001. Ms. Keegan may be contacted by telephone at (800) 368-5642, extension 8517, or by e-mail at [Elaine.Keegan@nrc.gov](mailto:Elaine.Keegan@nrc.gov)

Dated at Rockville, Maryland, this 13th day of May, 2011.

For the Nuclear Regulatory Commission.

**David J. Wrona,**

*Chief, Projects Branch 2, Division of License Renewal, Office of Nuclear Reactor Regulation.*

[FR Doc. 2011-12447 Filed 5-19-11; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket No. 72-26; NRC-2011-0110]

### Diablo Canyon Independent Spent Fuel Storage Installation; Notice of Docketing for Amendment Request No. 2 to Special Nuclear Materials License No. 2511

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of Docketing of Amendment Request for Materials License SNM-2511.

**DATES:** A request for hearing and/or petition for leave to intervene must be filed by July 19, 2011.

**FOR FURTHER INFORMATION CONTACT:** John M. Goshen, Project Manager, Licensing Branch, Division of Spent Fuel Storage and Transportation, Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, *telephone:* 301-492-3325; *fax number:* 301-492-3348; *e-mail:* [john.goshen@nrc.gov](mailto:john.goshen@nrc.gov).

#### SUPPLEMENTARY INFORMATION:

#### I. Introduction

The U.S. Nuclear Regulatory Commission (NRC or Commission) is considering an application dated January 31, 2011, from Pacific Gas and Electric Company (PG&E) to amend its Special Nuclear Material License No. SNM-2511, under the provisions of 10 CFR part 72, for the receipt, possession, storage and transfer of spent fuel, reactor-related Greater than Class C waste and other radioactive materials associated with spent fuel storage at the Diablo Canyon Independent Spent Fuel Storage Installation (ISFSI), located at the Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2 site in San Luis Obispo County, California. If granted, the amendment will revise Materials License SNM-2511 as follows:

#### 1. Changes to Technical Specifications (TS):

a. TS 1.1, "Definitions," is revised to include terms in support of high burnup fuel (HBF) selection criteria and the addition of neutron source assemblies (NSAs), and instrument tube tie rods (ITTRs).

b. TS 2.0, "Approved Contents," is revised in Tables 2.1-1 through 2.1-10 in support of HBF selection criteria and the addition of NSAs, and ITTRs.

c. TS 2.0, "Approved Contents," is revised to add new TS 2.3 and associated Table 2.3-1 to provide alternative calculations for burnup limits for fuel assemblies in a Multi-Purpose Canister (MPC)-32 to allow selection of HBF.

d. TS 3.1.1, "Multi-Purpose Canister (MPC)," is revised to eliminate the vacuum drying option, which is not allowed for HBF, and to add a reference temperature of 70 °F for the MPC Helium backfill pressure range.

e. TS 3.1.2, "Spent Fuel Storage Cask (SFSC) Heat Removal System," is modified to allow the HI-STORM to be considered operable with up to 50 percent vent blockage (although removal of any blockage is still required on discovery).

f. TS 3.1.4, "Supplemental Cooling System," is added to provide the conditions and criteria for the supplemental cooling system (SCS). This change requires an exemption from the requirements of 10 CFR 72.236(f). TS 4.1.2b, "Design Features Important to Criticality Control," is revised to change the B4C content in METAMIC to 33.0 wt%.

g. TS 5.1.3b, "MPC and SFSC Loading, Unloading, and Preparation Program," is revised to delete the requirement for maintaining the annulus full during vacuum drying and to restore the requirement for maintaining the annulus full during reflood (unloading).

2. Revision of the licensing basis as documented in the DC ISFSI Final Safety Analysis Report Update (FSARU) to:

a. Upgrade the thermal analysis methodology to a three dimensional (3D) Computational Fluid Dynamics (CFD) model,

b. Remove the requirement for 100% fuel failure coincident with 100% vent blockage,

c. Change of some allowed component temperatures in the thermal evaluation (peak cladding, concrete, overpack metal, transfer cask lid neutron shielding),

d. Reduce the required torque criteria for the MPC lift cleats, and

e. Addition of design criteria for the SCS including a new accident for loss of SCS.

3. An exemption from the requirements of 10 CFR 72.236(f) to allow use of a nonpassive SCS.

An NRC acceptance review, documented in a letter to PG&E dated April 14, 2011, found that the application contains sufficient information for the NRC staff to begin its technical review. This application was docketed under 10 CFR 72.16; the ISFSI Docket No. is 72-26 and will remain the same for this action. All other procedural requirements in Part 72 will be met as the NRC continues to process this license amendment request (see section II of this notice, "Opportunity to Request a Hearing").