

f. *Location*: On the Kentucky River in Mercer and Jessamine Counties, Kentucky.

g. *Filed Pursuant to*: Federal Power Act, 16 U.S.C. 791a–825r.

h. *Applicant Contact*: David Brown Kinloch, President/CEO, Lock 7 Hydro Partners, LLC, 414 S. Wenzel Street, Louisville, KY 40204, (502) 589–0975.

i. *FERC Contact*: M. Joseph Fayyad at (202) 502–8759, or email: mo.fayyad@ferc.gov.

j. *Deadline for filing comments, motions to intervene, and protests*: 30 days from issuance date of this notice by the Commission.

The Commission strongly encourages electronic filing. Please file any motion to intervene, protest, comments, and/or recommendations using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208–3676 (toll free), or (202) 502–8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. The first page of any filing should include docket number P–539–013.

k. *Description of Request*: Lock 7 Hydro Partners, LLC, requests Commission approval to replace the turbine runner for generating unit No. 2. The runner replacement would increase the installed and hydraulic capacities of the unit by 170 kilowatts (kW) and 157 cubic feet per second (cfs), respectively. The project's total installed capacity would change from 2,040 kW to 2,210 kW and its hydraulic capacity from 2,229 cfs to 2,386 cfs.

l. *Locations of the Application*: This filing may be viewed on the Commission's Web site at <http://www.ferc.gov/docs-filing/elibrary.asp>. Enter the docket number P–539 in the docket number field to access the document. You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, call 1–866–208–3676 or email FERCOnlineSupport@ferc.gov, for TTY, call (202) 502–8659. A copy is also available for inspection and

reproduction at the address in item (h) above and at the Commission's Public Reference Room, located at 888 First Street NE., Room 2A, Washington, DC 20426, or by calling (202) 502–8371.

m. Individuals desiring to be included on the Commission's mailing list should so indicate by writing to the Secretary of the Commission.

n. *Comments, Protests, or Motions To Intervene*: Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, .211, .214, respectively. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any comments, protests, or motions to intervene must be received on or before the specified comment date for the particular application.

o. *Filing and Service of Responsive Documents*: Any filing must (1) bear in all capital letters the title "COMMENTS", "PROTEST", or "MOTION TO INTERVENE" as applicable; (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. All comments, motions to intervene, or protests must set forth their evidentiary basis and otherwise comply with the requirements of 18 CFR 4.34(b). All comments, motions to intervene, or protests should relate to project works which are the subject of the license amendment. Agencies may obtain copies of the application directly from the applicant. A copy of any protest or motion to intervene must be served upon each representative of the applicant specified in the particular application. If an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the

Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

Dated: November 12, 2013.

Kimberly D. Bose,
Secretary.

[FR Doc. 2013–27609 Filed 11–18–13; 8:45 am]

BILLING CODE 6717–01–P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CD14–7–000]

South Tahoe Public Utility District; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On November 4, 2013, the South Tahoe Public Utility District filed a notice of intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act, as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The CHYDRO Project would be located along the existing C-Line export pipeline in South Tahoe Public Utility District's wastewater treatment system in Alpine County, California.

Applicant Contact: Richard Solbrig, South Tahoe Public Utility District, 1275 Meadow Crest Drive, South Lake Tahoe, CA 96150, Phone No. (530) 544–6474.

FERC Contact: Christopher Chaney, Phone No. (202) 502–6778, email: christopher.chaney@ferc.gov.

Qualifying Conduit Hydropower Facility Description: The proposed project would consist of: (1) A 12-inch-diameter intake pipe branching off the unconstructed, 18-inch-diameter Diamond Valley Ranch Loop pipeline; (2) an approximately 22-foot-wide by 35-foot-long powerhouse, containing one 55-kilowatt turbine/generating unit; (3) a 12-inch-diameter discharge pipe returning flow to the 18-inch-diameter Diamond Valley Ranch Loop; and (4) appurtenant facilities. The proposed project would have an estimated annual generating capacity of 2,135 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or deemed to meet all of the criteria shown in the table below.

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A), as amended by HREA.	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar man-made water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity.	Y
FPA 30(a)(3)(C)(i), as amended by HREA.	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y
FPA 30(a)(3)(C)(ii), as amended by HREA.	The facility has an installed capacity that does not exceed 5 megawatts	Y
FPA 30(a)(3)(C)(iii), as amended by HREA.	On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y

Preliminary Determination: Based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility not required to be licensed or exempted from licensing.

Comments and Motions To Intervene: Deadline for filing comments contesting whether the facility meets the qualifying criteria is 45 days from the issuance date of this notice.

Deadline for filing motions to intervene is 30 days from the issuance date of this notice.

Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

Filing and Service of Responsive Documents: All filings must (1) bear in all capital letters the “COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY” or “MOTION TO INTERVENE,” as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission’s regulations.¹ All comments contesting Commission staff’s preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the Commission’s eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your

name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

Locations of Notice of Intent: Copies of the notice of intent can be obtained directly from the applicant or such copies can be viewed and reproduced at the Commission in its Public Reference Room, Room 2A, 888 First Street NE., Washington, DC 20426. The filing may also be viewed on the Web at <http://www.ferc.gov/docs-filing/elibrary.asp> using the “eLibrary” link. Enter the docket number (e.g., CD14-7) in the docket number field to access the document. For assistance, call toll-free 1-866-208-3676 or email FERCOnlineSupport@ferc.gov. For TTY, call (202) 502-8659.

Dated: November 12, 2013.

Kimberly D. Bose,

Secretary.

[FR Doc. 2013-27608 Filed 11-18-13; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CD14-8-000]

Massachusetts Water Resources Authority; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On November 5, 2013, the Massachusetts Water Resources Authority filed a notice of intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act, as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The Chicopee Valley Aqueduct—Fish Hatchery Pipeline Project would be located along the proposed McLaughlin Fish Hatchery Pipeline at the Massachusetts Water Resources Authority’s Ware Disinfection Facility in Hampshire County, Massachusetts.

Applicant Contact: Pamela Heidell, Massachusetts Water Resources Authority, 100 First Avenue, Charlestown Navy Yard, Boston, MA 02129, Phone No. (617) 788-1102.

FERC Contact: Christopher Chaney, Phone No. (202) 502-6778, email: christopher.chaney@ferc.gov.

Qualifying Conduit Hydropower Facility Description: The proposed project would consist of: (1) An approximately 21-foot-wide by 38-foot-long underground powerhouse vault, containing one 59-kilowatt turbine/generating unit in line with the proposed 20-inch-diameter McLaughlin Fish Hatchery Pipeline; and (2) appurtenant facilities. The proposed project would have an estimated annual generating capacity of 447 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or

¹ 18 CFR 385.2001–2005 (2013).