

comment period in 2012 were addressed as part of developing this proposed revision of DG-1285. Documentation of the NRC's resolution of public comments on DG-1285 from 2012 are available in ADAMS under Accession No. ML16348A180.

III. Backfitting and Issue Finality

Draft guide 1285 describes an approach that the NRC staff considers acceptable for applications for licensing basis changes by considering engineering issues and applying risk insights at light-water reactors. Issuance of this DG, if finalized, would not constitute backfitting as defined in section 50.109 of title 10 of the Code of Federal Regulations (10 CFR) (the Backfit Rule) and would not otherwise be inconsistent with the issue finality provisions in 10 CFR part 52. As discussed in the "Implementation" section of this DG, the NRC has no current intention to impose this guidance, if finalized, on holders of current operating licenses or combined licenses.

This DG may be applied to applications for amendments to operating licenses or combined licenses docketed by the NRC as of the date of issuance of the final regulatory guide, as well as future applications submitted after the issuance of the regulatory guide. Such action would not constitute backfitting as defined in the Backfit Rule or be otherwise inconsistent with the applicable issue finality provision in 10 CFR part 52, inasmuch as such applicants or potential applicants are not within the scope of entities protected by the Backfit Rule or the relevant issue finality provisions in part 52.

Dated at Rockville, Maryland, this 3rd day of April 2017.

For the Nuclear Regulatory Commission.

Thomas H. Boyce,

Chief, Regulatory Guidance and Generic Issues Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. 2017-06939 Filed 4-6-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2017-2017-0065]

Information Collection: NRC Form 5, Occupational Dose Record for a Monitoring Period

AGENCY: Nuclear Regulatory Commission.

ACTION: Renewal of existing information collection; request for comment.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) invites public comment on the renewal of Office of Management and Budget (OMB) approval for an existing collection of information. The information collection is entitled, NRC Form 5, "Occupational Dose Record for a Monitoring Period."

DATES: Submit comments by June 6, 2017. Comments received after this date will be considered if it is practical to do so, but the Commission is able to ensure consideration only for comments received on or before this date.

ADDRESSES: You may submit comments by any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0065. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *Mail comments to:* David Cullison, Office of the Chief Information Officer, Mail Stop: T-5 F53, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on obtaining information and submitting comments, see "Obtaining Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT:

David Cullison, Office of the Chief Information Officer, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2084; email: INFOCOLLECTS.Resource@NRC.GOV.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2017-0065 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- *Federal rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0065.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS

Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. A copy of the collection of information and related instructions may be obtained without charge by accessing ADAMS Accession No. ML17090A545. The supporting statement and Occupational Dose Record for a Monitoring Period is available in ADAMS under Accession No. ML16357A680.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

- *NRC's Clearance Officer:* A copy of the collection of information and related instructions may be obtained without charge by contacting NRC's Clearance Officer, David Cullison, Office of the Chief Information Officer, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2084; email: INFOCOLLECTS.Resource@NRC.GOV.

B. Submitting Comments

Please include Docket ID NRC-2017-0065 in the subject line of your comment submission, in order to ensure that the NRC is able to make your comment submission available to the public in this docket.

The NRC cautions you not to include identifying or contact information in comment submissions that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enter the comment submissions into ADAMS, and the NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Background

In accordance with the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35), the NRC is requesting public comment on its intention to request the OMB's approval for the information collection summarized below.

1. *The title of the information collection:* NRC Form 5, "Occupational Dose Record for a Monitoring Period."
2. *OMB approval number:* 3150-0006.
3. *Type of submission:* Extension.
4. *The form number, if applicable:* NRC Form 5.
5. *How often the collection is required or requested:* Annually.
6. *Who will be required or asked to respond:* NRC licensees who are required to comply with part 20 of title 10 of the *Code of Federal Regulations* (10 CFR).
7. *The estimated number of annual responses:* 4,339 (198 reporting responses plus 4,141 record keepers).
8. *The estimated number of annual respondents:* 4,141 respondents (99 reactors plus 4,042 materials licensees).
9. *The estimated number of hours needed annually to comply with the information collection requirement or request:* 125,383 hours (5,940 hours reporting plus 119,443 hours recordkeeping).
10. *Abstract:* NRC Form 5 is used to record and report the results of individual monitoring for occupational radiation exposure during a monitoring period (one calendar year) to ensure regulatory compliance with annual radiation dose limits specified in 10 CFR 20.1201.

III. Specific Requests for Comments

The NRC is seeking comments that address the following questions:

1. Is the proposed collection of information necessary for the NRC to properly perform its functions? Does the information have practical utility?
2. Is the estimate of the burden of the information collection accurate?
3. Is there a way to enhance the quality, utility, and clarity of the information to be collected?
4. How can the burden of the information collection on respondents be minimized, including the use of automated collection techniques or other forms of information technology?

Dated at Rockville, Maryland, this 3rd day of April 2017.

For the Nuclear Regulatory Commission.

David Cullison,

NRC Clearance Officer, Office of the Chief Information Officer.

[FR Doc. 2017-06941 Filed 4-6-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-027 and 52-028; NRC-2008-0441]

South Carolina Electric & Gas Company; South Carolina Public Service Authority; Virgil C. Summer Nuclear Station, Units 2 and 3; Automatic Depressurization System Stage 2, 3 & 4, Valve Flow Area Changes and Clarifications

AGENCY: Nuclear Regulatory Commission.

ACTION: Exemption and combined license amendment; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 64 to Combined Licenses (COLs), NPF-93 and NPF-94. The COLs were issued to South Carolina Electric & Gas Company and the South Carolina Public Service Authority, (both collectively referred to as the licensee) for construction and operation of the Virgil C. Summer Nuclear Station (VCSNS) Units 2 and 3, located in Fairfield County, South Carolina.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

DATES: The exemption and amendment were issued on March 17, 2017.

ADDRESSES: Please refer to Docket ID NRC-2008-0441 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0441. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select

"ADAMS Public Documents" and then select "*Begin Web-based ADAMS Search.*" For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated September 2, 2016, and it is available in ADAMS under Accession No. ML16246A214.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: Ruth C. Reyes, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-3249; email: Ruth.Reyes@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The NRC is granting an exemption from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 64 to COLs, NPF-93 and NPF-94, to the licensee. The exemption is required by paragraph A.4 of Section VIII, "Processes for Changes and Departures," of appendix D, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes that would allow changes in appendix C of the COLs to clarify the flow area for the automatic depressurization system (ADS) fourth stage squib valves and to reduce the minimum effective flow area for the second and third stage ADS control valves.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, and 52.7, and Section VIII.A.4 of appendix D to 10 CFR part