

submission to the OMB, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that comment submissions are not routinely edited to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Background

Under the provisions of the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35), the NRC recently submitted a proposed collection of information which included a request for extension of an existing collection of information to OMB for review entitled, "The Office of Nuclear Material Safety and Safeguards Requests for Information on 10 CFR part 150, Exemptions and Continued Regulatory Authority in Agreement States and in Offshore Waters Under Section 274 of the Atomic Energy Act of 1954." The NRC hereby informs potential respondents that an agency may not conduct or sponsor, and that a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

The NRC published a **Federal Register** notice with a 60-day comment period on this information collection on October 10, 2018, (83 FR 50969).

1. *The title of the information collection:* 10 CFR part 150, Exemptions and Continued Regulatory Authority in Agreement States and in Offshore Waters Under Section 274 of the Atomic Energy Act of 1954.

2. *OMB approval number:* 3150-0032.

3. *Type of submission:* Extension.

4. *The form number if applicable:* N/A.

5. *How often the collection is required or requested:* One-time or as-needed.

6. *Who will be required or asked to respond:* Agreement States who have signed Section 274(b) Agreements with the NRC.

7. *The estimated number of annual responses:* 8.

8. *The estimated number of annual respondents:* 8.

9. *An estimate of the total number of hours needed annually to comply with the Information collection requirement or request:* 190.

10. *Abstract:* The Nuclear Regulatory Commission (NRC) regulations in part 150 of Title 10 of the *Code of Federal Regulations* (10 CFR), provide certain exemptions to persons in Agreement States from the licensing requirements contained in Chapters 6, 7, and 8 of the Atomic Energy Act of 1954, as amended,

and certain regulations of the Commission. The regulations in 10 CFR part 150 also define the Commission's continued regulatory authority over Agreement State activities which include byproduct, source, and special nuclear material reporting requirements related to reciprocity and enforcement. There exists a need for the NRC to gather information concerning the application, recordkeeping, and reporting requirements imposed by specific sections of 10 CFR part 150.

Dated at Rockville, Maryland, this 12th day of March 2019.

For the Nuclear Regulatory Commission.

Kristen E. Benney,

Acting NRC Clearance Officer, Office of the Chief Information Officer.

[FR Doc. 2019-04910 Filed 3-15-19; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4, Reactor Coolant System Flow Coastdown

AGENCY: Nuclear Regulatory Commission.

ACTION: Exemption and combined license amendment; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment Nos. 155 and 154 to Combined Licenses (COL), NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, and the City of Dalton, Georgia (collectively SNC); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia. The granting of the exemption allows the changes to Tier 1 information requested in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

DATES: The exemption and amendment were issued on February 25, 2019.

ADDRESSES: Please refer to Docket ID NRC-2008-0252 when contacting the

NRC about the availability of information regarding this document. You may obtain publicly available information related to this document using any of the following methods:

- **Federal Rulemaking Website:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC docket IDs to Krupskaya Castellon; telephone: 301-287-9221; email: Krupskaya.Castellon@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- **NRC's Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated August 31, 2018 (ADAMS Accession No. ML18243A459).

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: Peter Hearn, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-1189; email: Peter.Hearn@NRC.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The NRC is granting exemptions from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment Nos. 155 and 154 to COLs, NPF-91 and NPF-92, to SNC. The exemptions are required by paragraph A.4 of section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52 to allow SNC to depart from Tier 1 information. With the requested amendment, SNC sought proposed changes that would revise the initial test program in the Updated Final Safety Analysis Report Tier 2 information. The

proposed amendment also involves DCD Tier 2* and Tier 2 information and related changes to the VEGP Units 3 and 4 COL and plant-specific Tier 1 information, with corresponding changes to the associated COL Appendix C information.

Part of the justification for granting the exemptions was provided by the review of the amendments. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemptions and issued the amendments concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemptions met all applicable regulatory criteria set forth in sections 50.12, 10 CFR 52.7, and section VIII.A.4 of appendix D to 10 CFR part 52. The license amendments were found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML19038A458.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to SNC for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML19038A452 and ML19038A453, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML19038A454 and ML19038A456, respectively. A summary of the amendment documents is provided in Section III of this document.

II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated August 31, 2018, the Southern Nuclear Operating Company (SNC) requested from the Nuclear Regulatory Commission (NRC or Commission) an exemption to allow departures from Tier 1 information in the certified DCD incorporated by reference in Title 10 of the *Code of Federal Regulations* (10 CFR) part 52, appendix D, "Design Certification Rule for the AP1000 Design," as part of license amendment request (LAR) 18-025, "Reactor Coolant System (RCS) Flow Coastdown."

For the reasons set forth in Section 3.2 of the NRC staff's Safety Evaluation, which can be found at Agencywide Documents Access and Management System (ADAMS) Accession Number ML19038A458, the Commission finds that:

A. The exemption is authorized by law;

B. the exemption presents no undue risk to public health and safety;

C. the exemption is consistent with the common defense and security;

D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, SNC is granted an exemption from the certified DCD Tier 1 information, with corresponding changes to Appendix C of the facility Combined License as described in SNC's request dated August 31, 2018. This exemption is related to, and necessary for, the granting of License Amendment No. 155 [for Unit 3, 154 for Unit 4], which is being issued concurrently with this exemption.

3. As explained in Section 5.0 of the NRC staff's Safety Evaluation (ADAMS Accession Number ML19038A458) this exemption meets the eligibility criteria for categorical exclusion, set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

III. License Amendment Request

By letter dated August 31, 2018 (ADAMS Accession No. ML18243A459), SNC requested that the NRC amend the COLs for VEGP, Units 3 and 4, COL Nos. NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on October 23, 2018 (83 FR 53515). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that SNC requested on August 31, 2018. The exemptions and amendments were issued on February 25, 2019, as part of a combined package to SNC (ADAMS Package Accession No. ML19038A450).

Dated at Rockville, Maryland, this 13th day of March 2019.

For the Nuclear Regulatory Commission.

Jennifer L. Dixon-Herrity,

Chief, Licensing Branch 2, Division of Licensing, Siting, and Environmental Analysis, Office of New Reactors.

[FR Doc. 2019-04958 Filed 3-15-19; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

662nd Meeting of the Advisory Committee on Reactor Safeguards (ACRS)

In accordance with the purposes of Sections 29 and 182b of the Atomic Energy Act (42 U.S.C. 2039, 2232b), the Advisory Committee on Reactor Safeguards (ACRS) will hold meetings on April 4-6, 2019, Two White Flint North, 11545 Rockville Pike, Conference Room T2D10, Rockville, MD 20852.

Thursday, April 4, 2019, Conference Room T2D10

8:30 a.m.-8:35 a.m.: Opening Remarks by the ACRS Chairman (Open)—The ACRS Chairman will make opening remarks regarding the conduct of the meeting.

8:35 a.m.-12:00 p.m.: NuScale Safety Evaluation Report for Chapters 9, 10, 11, 12 and 16 (Open/Closed)*—The Committee will have briefings by and discussion with representatives of the